

DĖL PIRKIMO SĄLYGŲ PATIKSLINIMO

LITGRID AB pirkimų komisija (toliau – Komisija) atviro konkuro būdu vykdo 410/345/10,5 kV autotransformatoriaus pirkimą (toliau – Pirkimas).

Informuojame, kad vadovaujantis Bendrųjų Pirkimo sąlygų 15.5 punktu ir atsižvelgiant į tai, kad Komisija pastebėjo Pirkimo dokumentuose klaidų ir vietų, reikalingų paaiškinimo, Komisija patikslino šiuos Pirkimo dokumentus:

1. Specialiųjų Pirkimo sąlygų 8 priedą Ekonomiškai naudingiausio pasiūlymo vertinimo metodiką, kurioje patikslino Energijos nuostolių, apskaičiuotų 35 metų laikotarpiui, sąnaudų (P) apskaičiavimo formulę, kad ji atitiktų perkamo autotransformatoriaus galią ir kiekį (1 vnt.);
2. Pasiūlymo formos 1 priedėlį, kuriame patikslintos perkamo autotransformatoriaus įtampos;
3. Techninės specifikacijos 1 priedą, kuriame pridėtas paaiškinimas dėl autotransformatoriaus įtampų:
„*400 kV, 330 kV ir 10 kV yra elektros perdavimo tinklų, prie kurių prijungiamas autotransformatorius, nominalios įtampos. Kiekvienos apvijos detalesnės įtampų charakteristikos pateikiamos autotransformatoriaus specifikacijoje.“

Pridedama:

1. Patikslintas Specialiųjų Pirkimo sąlygų 8 priedas Ekonomiškai naudingiausio pasiūlymo vertinimo metodika;
2. Patikslintas Pasiūlymo formos 1 priedėlis;
3. Patikslintas techninės specifikacijos 1 priedas.

REGARDING THE CLARIFICATIONS OF THE PROCUREMENT CONDITIONS

The Procurement Commission of LITGRID AB (hereinafter – Commission) is conducting the Procurement of 410/345/10,5 kV autotransformer by open tender (hereinafter – Procurement).

Please be informed that in accordance with Clause 15.5 of the General Procurement Conditions and considering that the Commission noticed errors and places requiring clarification in the Procurement documents, the Commission has clarified the following Procurement documents:

1. Annex 8 of the Special Procurement Conditions, the Methodology for Evaluating the Most Economically Advantageous Tender, in which the formula for calculating the costs of energy losses over a 35-year period (P) has been adjusted to match the power and quantity (1 unit) of the purchased autotransformer;
2. Appendix 1 to the Tender Form, in which the voltages of the purchased autotransformer have been clarified;
3. Annex 1 of the Technical Specification, which includes an explanation of the autotransformer voltages:
“*400 kV, 330 kV, and 10 kV are the nominal voltages of the electricity transmission grid to which the autotransformer is connected. Detailed voltage characteristics of each winding are provided in the autotransformer specification.”

Attached:

1. Revised Annex 8 to the Special Procurement Conditions, Methodology for Evaluating the Most Economically Advantageous Tender;
2. Revised Appendix 1 to the Proposal Form;
3. Revised Annex 1 to the Technical Specification.”

Edita Kazakevičienė, tel./phone: +370 678 22275, el. p./e-mail: Edita.Kazakeviciene@litgrid.eu