

VIRA ISI VE ENDÜSTRİYEL URUNLER A.S.

İKİTELLİ ORG. SAN. BOL. METAL İŞ SAN. SİT.
11.BLOK NO.37-39 BAŞAKŞEHİR
İSTANBUL / TURKEY

**24.07.2024**

EN 10204 type 2.2	QUALITY CERTIFICATE	No.24127
Customer Number : 13241 Invoice Number : 24341 Invoice Date : 26.07.2024	Customer Name : UAB ELMITRA Contract No : Address : Raudondvario pl. 150, LT-47175 Kaunas, Lithuania	

Test certificates are published by test reports by following ;

The certificate is only valid for following order ;

Pos.	Vira Code	Description	Size	Quantity
1	SVH-F	ViraVent, steel high-flow deaerator with stainless steel low resistance filter. Flanged unit suitable up to 10 bar, 110°C	DN 200	1
2	SVH-F	ViraVent, steel high-flow deaerator with stainless steel low resistance filter. Flanged unit suitable up to 10 bar, 110°C	DN 250	1
3	SVH-F	ViraVent, steel high-flow deaerator with stainless steel low resistance filter. Flanged unit suitable up to 10 bar, 110°C	DN 300	1

Applicable EU Directive : 2014/68/EU Simple Pressure Equipment Directives

No.	Applied Tests	Time	Pressure	Time	Product	Statue	Serial Number
1	Hydrostatic Test	14:00	20 barg	10 min	SVH-F / DN 200	Approved	24LT08SVH001
	Hydrostatic Test	14:50	20 barg	10 min	SVH-F / DN 250	Approved	24LT08SVH002
	Hydrostatic Test	16:00	20 barg	10 min	SVH-F / DN 300	Approved	24LT08SVH003
2	Welding Eyesight Control					Approved	

Q/C tests as following

Working Under Pressure ✓
Airvent Test ✓
Leakage Test ✓

M.Eren Cengiz
General Manager

VIRA
ISI VE ENDÜSTRİYEL ÜRÜNLER A.Ş.
İkitelli Org. San. Bol. Metal İş San. Sit.
11. Blok No:37-39 BAŞAKŞEHİR / İSTANBUL
İKİTELLİ V.D. - 925 039 6358

Gökhan Yeşilyurt
Manufacturing Engineer

VIRA
ISI VE ENDÜSTRİYEL ÜRÜNLER A.Ş.
İkitelli Org. San. Bol. Metal İş San. Sit.
11. Blok No:37-39 BAŞAKŞEHİR / İSTANBUL
İKİTELLİ V.D. - 925 039 6358

Vira Isı ve Endüstriyel Ürünler A.S.

İKİTELLİ ORG. SAN. BOL. METAL İŞ SAN. SİT. 11.BLOK NO.37-39 BAŞAKŞEHİR İSTANBUL / TURKEY
Tel : +90 212 549 5770 - Fax : +90 212 549 5848 - Email : info@viraisi.com

Test report certificate number : MANU8041